



PHILIPPINE HEART CENTER
East Avenue, Quezon City

SUPPLEMENTAL BID BULLETIN No. 021-2023

SUBJECT : Revisions in the Technical Specifications

PROJECT/S : 1 Lot Supply of Labor and Materials Including Installation of 6 units 250 kgs. Per tank of Liquefied Petroleum Gas (LPG) with a total volume of 1500 kgs. - ITB No. 016.23


To ensure that the transactions are comparatively advantageous to the interests of the PHC, the originally pre-issued bidding documents, thus, revisions/changes are introduced.

Page No/ Item No.	PHC- Technical Specification	Clarifications/Amended "Should be read as"
Page 10	2. Delivery Period = 10 calendar days	2. Delivery Period = 90 calendar days
Page 39	1. 120 AG LPG Tank with Overfill Protection Device (Made in Mexico, U.S. or Equivalent)) - 250 KGS. Capacity	1. "Brand New" 120 AG LPG Tank with Overfill Protection Device (Made in Mexico, U.S. or Equivalent)) - 250 KGS. Capacity
	2. Central Panel (Made in Italy, U.S. or equivalent) - Power Supply: 230Vca, 50-60Hz - Absorption: 10 Va - Alarm Level: 10-20% L.E.L	2. "Brand New" Central Panel (Made in Italy, U.S. or equivalent) - Power Supply: 230Vca, 50-60Hz - Absorption: 10 Va - Alarm Level: 10-20% L.E.L
	3. Siren (Made in Italy, U.S. or equivalent) - Power Supply: 230Vca, 50-60Hz/12V - Absorption: 15Va - Sound Intensity: 115db	3. "Brand New" Siren (Made in Italy, U.S. or equivalent) - Power Supply: 230Vca, 50-60Hz/12V - Absorption: 15Va - Sound Intensity: 115db
	4. Explosion Proof Gas Leak Detector (Made in Italy, U.S. or equivalent) - Power Supply: 12Vdc - Absorption: 1W - Output: 4-20mA - Measuring Range: 0-20% L.E.L - Sensor: Catalytic	4. "Brand New" Explosion Proof Gas Leak Detector (Made in Italy, U.S. or equivalent) - Power Supply: 12Vdc - Absorption: 1W - Output: 4-20mA - Measuring Range: 0-20% L.E.L - Sensor: Catalytic
	5. Ball Valve (Made in Italy, U.S. or equivalent) - CSA-UL-FM Certified	5. "Brand New" Ball Valve (Made in Italy, U.S. or equivalent) - CSA-UL-FM Certified
	6. High Pressure (HP) Regulator (Made in Italy, U.S. or equivalent) - Capacity: 10,700,000 BTU/HR - Outlet Pressure Range: 5-20 PSIG	6. "Brand New" High Pressure (HP) Regulator (Made in Italy, U.S. or equivalent) - Capacity: 10,700,000 BTU/HR - Outlet Pressure Range: 5-20 PSIG
	7. Automatic Solenoid Shut Off Valve N.O. (Made in Italy, U.S. or equivalent) - Power Supply: 230Vca, 50-60Hz - Closing Time: less than 1 set - Max Pressure: 550 mbar/6 bar	7. "Brand New" Automatic Solenoid Shut Off Valve N.O. (Made in Italy, U.S. or equivalent) - Power Supply: 230Vca, 50-60Hz - Closing Time: less than 1 set - Max Pressure: 550 mbar/6 bar
		8. Additional Requirements: Tapping Point of LPG Lines - From Brand New Manifold up to DND Isolation Valve and Cafe 1475 Isolation Valve - B1 Pipe and B1 Fittings, Schedule 80

This Supplemental Bid Bulletin is hereby issued to modify the original parameters as stated therein. All other requirements previously stated on the bid documents must be complied.

Please be guided accordingly.

Approved. Done this 26th day of April 2023, BAC Office, PHC.



RANULFO B. JAVELOSA, JR., MD.
Chairman, BAC for Infrastructure, Med Supplies and Services