



PHILIPPINE HEART CENTER
East Avenue, Quezon City

SUPPLEMENTAL BID BULLETIN No. 032-2023

SUBJECT : Modification in the Bidding Documents
PROJECT/S : 1 Lot Supply of Labor and Materials for the Provision of Independent Electrical System for Annex Building Re-Bid - ITB No. 033.23

To ensure that the transactions are comparatively advantageous to the interests of the PHC, the originally pre-issued bidding documents, thus, revisions/changes are hereby introduced.

Page No/ Item No.	PHC- Technical Specification	Clarifications/Amended "Should be read as"
Page 24	5.3.b. Completed within the past 2 years prior to the deadline for the submission and receipts of bids.	5.3.b. Completed within the past 5 years prior to the deadline for the submission and receipts of bids.
Page 39	2. Technical Specifications: 2.1. 1 unit oil immersed pad mounted transformer	2. Technical Specifications: 2.1. 1 unit oil immersed pad mounted transformer - mineral oil
	2. 1 unit Free Standing Cabinet, NEMA 12 SIZE: At least 100 cm x 100 cm x 190 cm (LxDxH)	2. 1 unit Free Standing Cabinet, NEMA 12 SIZE: At least 100 cm x 100 cm x 190 cm (LxDxH) / Dead Front
	Additional Requirements:	1. Test Certificate for Performance Data of Transformer
		2. PCAB= Small B or C & D
		3. Factory Test – mandatory factory test prior to delivery
		4. Single Line Diagram – is available with the End-users

This Supplemental Bid Bulletin is hereby issued to modify the original parameters as stated therein. All other requirements previously stated on the bid documents must be complied.

Please be guided accordingly.

Approved Done this 19th day of May 2023, BAC Office, PHC.

RANULFO B. VAVELOSA, JR., MD.
Chairman, BAC for Infrastructure, Med Supplies and Services