



PHILIPPINE HEART CENTER  
East Avenue, Quezon City

**SUPPLEMENTAL BID BULLETIN No. 034-2024**

**SUBJECT : Revisions in the Bidding Documents**

**PROJECT : 1 Lot Supply of Labor and Materials for the Rehabilitation of Fire Detection and Alarm System - ITB No. 038.24**

\*\*\*\*\*  
To ensure that the transactions are comparatively advantageous to the interests of the PHC, the originally pre-issued bidding documents as mentioned above, revised technical specifications are hereby introduced

<b>Page No/ Item No.</b>	<b>PHC- Technical Specification FROM</b>	<b>Clarifications/Amended “Should be read as“ TO</b>
Page 1 & Page 39	Technical Specification: Project Title: 1 Lot Supply of Labor and Materials for the Rehabilitation of Fire Detection and Alarm System	Project Title: 1 Lot <b>Upgrading of Fire Detection and Alarm System</b>
	3.1. Addressable Main Fire Alarm Panel with Battery: 1 set	3.1. Addressable Main Fire Alarm Panel with Battery: <b>1 set ; Input Voltage Range: 100—240 Vac, 60 Hz</b>
	3.2. Addressable Sub Fire Alarm Panel with Battery: 3 sets	3.2. Addressable Sub Fire Alarm Panel at least 32 loops or 63 zones with Battery: <b>3 sets ; Input Voltage Range: 100—240 Vac, 60 Hz</b>
	3.3. Repeater Panel: 18 units	3.3. <b>LED Annunciator Panel 18 units maximum of 32 outputs with flashing</b>
	3.5. Addressable Smoke Detectors :781 pcs.	3.5. Addressable Smoke Detectors <b>Optical Sensor Dual Ray and EMC Compatibility Data; Operating Voltage 12-33Vdc</b>
	3.6. Addressable Heat Detectors: 238 pcs.	3.6. Addressable Heat Detectors <b>Operating Voltage 12-33Vdc</b>
	3.8. Addressable Manual Call Point	3.8. Addressable Manual Call Point; <b>Operating Voltage 12-33Vdc/9-15Vdc</b>

	3.9. Addressable sounder with flasher	3.8. Addressable Manual Call Point; Sound Pressure Level 90-112 Db (A), Operating Voltage 12-33Vdc
	<b>Additional Requirements:</b>	
	Codes and Standards	UL/EN/VdS or approved equal
	Environmental Factor; Operating Temperature	Ambient temperature of 20-30 deg C and at least 70% humidity
	Storage Temperature	Ambient temperature of 0-50 deg C and humidity of 15-90%

This Supplemental Bid Bulletin is hereby issued to modify the original parameters as stated therein. All other requirements previously stated on the bid documents must be complied.

Please be guided accordingly.

**Approved.** Done this 16<sup>th</sup> day of May 2024, BAC Office, PHC.

  
**RANULFO B. JAVELOSA, JR., MD.**  
 Chairman, BAC for Infrastructure, Medical Supplies & Services