



PHILIPPINE HEART CENTER  
East Avenue, Quezon City

**SUPPLEMENTAL BID BULLETIN No. 040-2022**

**SUBJECT : Revision in the Bidding Documents**

**PROJECT : 4 units Supply of Labor and Materials for the Replacement of 4-sets Air Conditioner- Laminar Flow System - ITB.042.22**

\*\*\*\*\*

To ensure that the transactions are comparatively advantageous to the interests of the PHC, the originally pre-issued technical specification as mentioned above, revisions/changes are hereby introduced.

ITB No.	PHC – Technical Specifications FROM	Clarifications/Modifications (Should be read as) TO
Page 10	Delivery Period: 90 calendar days	Delivery Period: <u>150 calendar days</u>
Page 38		<b>For Inclusion:</b>  <b>Should be Certified by Air Movement and Control Association International, Inc. or equivalent</b>

This Supplemental Bid Bulletin is hereby issued to modify the original parameters as stated therein. All other requirements previously stated on the bid documents must be complied.

Please be guided accordingly.

Approved. Done this 25<sup>st</sup> day of July 2022, BAC Office, PHC.

**RANULFO B. JAVELOSA, JR., MD.**  
Chairman, BAC for Infra, Med Supplies and Services