



PHILIPPINE HEART CENTER
East Avenue, Quezon City
SUPPLEMENTAL BID BULLETIN No. 056-2022

SUBJECT : Revision in the Bidding Documents

PROJECT : 1 Lot Supply of Labor and Materials for the Conversion of 10 units Conventional to Compact Air-Handling Units (AHU) at Hospital Building/MAB - ITB.062.22

To ensure that the transactions are comparatively advantageous to the interests of the PHC, the originally pre-issued technical specification as mentioned above, revision/change is hereby introduced.

ITB No.	<u>PHC – Technical Specifications</u> <u>FROM</u>	<u>Clarifications/Modifications (Should be read as)</u> <u>TO</u>
Page 37	Item No. 3.3. 1 unit Air Handling Unit (AHU 35) Draw Thru Floor Mounted Up Blast, 365,000 BTU/Hr., Total Air: 12,000 cfm @ 2.3S.P., Coil: 6 Rows, 12 Fins/inch 350 fpm Face Velocity, Air Filter: Hepa Filter i99.99% efficiency @ 0.3 um, Pre- filter: 2” 3M Nylon or equivalent, Motor Controls (Soft-Start) and Panel, Rust- proof drain pan, Air bleed valve, Darin Valve, Temperature Gauges	To be deleted (Same with Page 38- Item No. 3.3)

This Supplemental Bid Bulletin is hereby issued to modify the original parameters as stated therein. All other requirements previously stated on the bid documents must be complied.

Please be guided accordingly.

Approved. Done this 13th day of September 2022, BAC Office, PHC.


RANULFO B. JAVELOSA, JR., MD.
 Chairman, BAC for Infra, Med Supplies and Services