



PHILIPPINE HEART CENTER
East Avenue, Quezon City

SUPPLEMENTAL BID BULLETIN No. 058-2022

SUBJECT : Revision in the Bidding Documents

PROJECT : 1 Lot Supply of Labor and Materials for the Conversion of 10 units Conventional to Compact Air-Handling Units (AHU) at Hospital Building/MAB - ITB.062.22

To ensure that the transactions are comparatively advantageous to the interests of the PHC, the originally pre-issued technical specification as mentioned above, revisions/changes are hereby introduced.

ITB No.	<u>PHC – Technical Specifications</u> <u>FROM</u>	<u>Clarifications/Modifications (Should be read as)</u> <u>TO</u>
Page 38		3.11. For Inclusion: 1. AMCA and AHRI Air Handling Unit (AHU) certification are required. 2. AHU accessories like magnehelic differential gauge, sight glass and marine light inside AHU are required.

This Supplemental Bid Bulletin is hereby issued to modify the original parameters as stated therein. All other requirements previously stated on the bid documents must be complied.

Please be guided accordingly.

Approved. Done this 14th day of September 2022, BAC Office, PHC.


RANULFO B. JAVELOSA, JR., MD.
Chairman, BAC for Infra, Med Supplies and Services